

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2686

Dated: 04/06/2025

It is certified that an inspection team headed by **Er. Pardeep Kumar** Sub Divisions Engineer Water & Sanitation Sub Division No. 2, **Manwal Bagh, Distt. Pathankot** inspected the **Richmond Convent School, Village Manwal Bagh, Distt. Pathankot** on **03/06/2025** and on the basis of Water Test Report (Attached) bearing no **262** dated **21/04/2025** of Distt. Water Testing Laboratory, Pathankot (Physical & Chemical Test) certified that the **Richmond Convent School, Village Manwal Bagh, Distt. Pathankot** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State.

This certificate is valid till **26/05/2026**.

Signature with Seal:

Executive Engineer,
WS & Sanitation Divn. No.2

Name : **RATHANKOT**

Designation : **Sukhjeet Singh**
Executive Engineer.

To

Richmond Convent School
Village Manwal Bagh,
Pathankot

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal **Komal Rana**
Richmond Convent School
Pathankot

Manager **Anand Kumar**
Richmond Convent School
Pathankot

DISTRICT WATER TESTING LABORATORY, PATHANKOT

District Administrative Complex, 1st Floor, D Block, Room No.235, Pathankot.
dwtlptk1@gmail.com

TC-13279

14

TEST REPORT

Name & Address of Customer : Richmondd Convent School. Richmondd Convent School. Manwal Bagh Pathankot		Customer Reference No. No : 262 Dated : 21/04/2025
Sample Submitted by		Amarjit Singh
Date of Sample Receipt		21/04/2025
Analysis Starting Date		21/04/2025
Analysis completion Date		22/04/2025
Discipline : Chemical Testing		Group: Water
ULR No.:	TC13279250000067F	Sample Type : Water
Test Report No.:	DWTLPTK/2526/00005	Date of Issue : 06/05/2025
Registration no.:	DWTLPTK/REG2526/00005	Condition of Sample : Unsealed
Collection Point:	Distribution Point(Near Bus stand,School,Gurudwara,etc)	Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : Richmondd Convent School.Manwal Bagh Pathankot. / NA
Village	Manwal	Habitation : Manwal
Block:	Pathankot	District : Pathankot
Latitude :	Not Mentioned	Longitude: Not Mentioned

No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.0@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	310	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	140	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	156	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	30.46	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	19.44	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	17.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Pathankot

End of the Test Report

Principal *Komal Rana*
Richmondd Convent School
Pathankot

Manager *Amarjit Singh*
Richmondd Convent School
Pathankot